

# Emission Test Certificate

Wednesday, 8<sup>th</sup> November, 2017

Supplier: Godfrey Hirst Australia (7 Factories Road, Geelong, VIC 3220)

Sample Description: Aussie Species GH Hybrid 5.5mm

Date Tested: October 2017 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D5116-97 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

Emission Data:

<b>Global GreenTag</b>	<b>Aussie Species GH Hybrid 5.5mm</b>
Total Volatile Organic Compound Emission Rate Limit: <0.500 mg/m <sup>2</sup> /hr	Total Volatile Organic Compound Emission Rate: 0.065 mg/m <sup>2</sup> /hr
4-phenylcyclohexene Emission Rate Limit: <0.05 mg/m <sup>2</sup> /hr	4-phenylcyclohexene Emission Rate: <0.003 mg/m <sup>2</sup> /hr
Formaldehyde Emission Rate Limit: <0.1 mg/m <sup>2</sup> /hr	Formaldehyde Emission Rate: 0.012 mg/m <sup>2</sup> /hr



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant



Nick Joy  
BSc(Hons)  
Consultant



Tuan Duong  
B.Eng. (Chemical)  
Consultant

CV171032